



Report ID: PT-28972

6301 Bearden Lane
Modesto, CA 95357
209.527.2908
fax
cal.powerhydrodynamics.com

CONFIDENTIAL/PROPRIETARY INFORMATION

Ralph Heringer
Rec Dist 2028 Bacon Island
P O Box 4005
Stockton, CA 95204

Thursday, Oct 03, 2024

SUBJECT: PUMPING COST ANALYSIS
HP: 75.00 Plant: West Pump 2
PUMP TEST REFERENCE NUMBER: PT-28972
PUMP TEST RUN: Run 1

The following Pumping Cost Analysis is presented as an aid to your cost accounting. This analysis is an estimate prepared from operating criteria supplied from the pump test performed Sep 30 2024 and information provided by you during the pump test.

It is recommended and assumed that:

- Overall plant efficiency can be improved to: 74%
- Water requirements will be the same as for the past year
- All operating conditions (annual hours of operation, discharge head, and water pumping level) will remain the same as they were at the time of the pump test

	EXISTING PLANT EFFICIENCY	IMPROVED PLANT EFFICIENCY	SAVINGS
kWh/AF	41.1	41.1	*
Estimated Total kWh	63,202	63,202	*
Average Cost per kWh	\$0.18	\$0.18	
Average Cost per hour	\$11.67	\$12.48	*
Cost Per Acre Ft.	\$7.58	\$7.58	*
Estimated Acre Ft. Per Year	1,538.43	1,538.43	
Run Hours	1,000.00	1,000.00	
Overall Plant Efficiency	74%	74%	
Estimated Total Annual Cost	\$11,668.31	\$11,668.31	*

It is sincerely hoped that this information will prove helpful to you, and that your concerns over maintaining optimum pumping efficiency will be continued. If you have any questions, please contact Bill Power at (209) 527-2908.

Regards,

William Thomas Power, III

Enclosures



Report ID: PT-28972

6301 Bearden Lane
Modesto, CA 95357
209.527.2908
fax
cal.powerhydrodynamics.com

Agricultural and Domestic Pump Test Report Rec Dist 2028 Bacon Island - West Pump 2 - Run 1

Latitude: 37.97924
Test Date: Sep 30 2024

Longitude: -121.57063
Tester: Devin Power

Elevation: -7
Nameplate HP: 75.00

Customer Information	Power Company Data	Equipment Data
Rec Dist 2028 Bacon Island	PG&E	Motor Make: General Electric
P O Box 4005	Meter #: 1010076943	Volts/Amps: 440V/91.00A
Stockton, CA 95204	Rate Schedule: AG5B	Serial #: TFJ679947
Contact: Ralph Heringer	Average Cost: \$0.18	Pump Make: No Name Plate
Cell: 916-777-6091		Pump Type: Mix Flow
		Drive Type: Electric Motor
		Gearhead Make:

Hydraulic Data	Flow Data
Pumping Water Level (PWL): 17.00 ft	Run Number: 1 of 1
Discharge Pressure: 5.50 PSI	Measured Flow: 8355 gpm
Discharge Level: 12.71 ft	Customer Flow: 0 gpm
Total Lift: 29.71 ft	Flow Velocity: 6.28 ft/sec
Water Source: Canal	Acre Feet per 24 Hr: 36.97
	Cubic Feet Per Second (CFS): 18.61 ft

Power Data	
Horsepower Input to Motor: 84.72 hp	Percent of Rated Motor Load: 103%
Brake Horsepower: 77.09 hp	Kilowatt Hours per Acre Foot: 41.08
Kilowatt Input to Motor: 63.2 kW	Cost to Pump an Acre Foot: \$7.58
Energy Cost: \$11.67/hr	Overall Plant Efficiency: 73.98%
Nameplate RPM: 1175 rpm	Water Horsepower: 62.67 hp
VFD: 0 hz	Run Hours: 1000

Remarks
All results are based on conditions during the time of the test. If these conditions vary from the normal operation of your pump, the results shown may not describe the pump's normal performance.
This pump has an adequate test section.
This pump did not have a flow meter.
Based on information obtained at the time the test was performed, this test represents the pumps standard operating conditions.
HPI measured with direct read KWI.
Overall efficiency of this plant is considered to be very good assuming this run represents plant's normal operating condition.



Report ID: PT-28972

6301 Bearden Lane
Modesto, CA 95357
209.527.2908
fax
cal.powerhydrodynamics.com

Ralph Heringer
Rec Dist 2028 Bacon Island
P O Box 4005
Stockton, CA 95204

Pump Name: West Pump 2

HYDRAULIC TEST RESULTS

PT-28972

Test Date: Sep 30 2024

Tester: Devin Power
Meter #: 1010076943
Annual Run Hrs: 1000

Utility: PG&E
Rate Sched: AG5B
Avg Cost kWh: \$0.18

Meter kH: 1.80
Meter Const: 80

Motor Make: General Electric
Volts: 440
Gearhead Make:
Pump Make: No Name Plate
Water Source: Canal

Motor Serial: TFJ679947
Amps: 91.00
Nameplate RPM: 1175
Pump Type: Mix Flow

Horsepower: 75.00
Drive Type: Electric Motor
Pipe Diameter: 23.31

Results

Test 1

Discharge Pressure, PSI	5.50
Standing Water Level, Feet	0
Recovered Water Level	0.00
Drawdown, Feet	17
Discharge Head, Feet	12.71
Pumping Water Level, Feet	17.00
Total Measured Head, Feet	29.705
Measured GPM	8355.00
Customer Meter, GPM	
Well Yield, GPM/ft Drawdown	491.47
Acre Feet Pumped in 24 Hours	36.97
kW Input to Motor	63.2
HP Input to Motor	84.72
Motor Load %	102.8
Measured Speed of Pump, RPM	
VFD, Hz:	
kWh per Acre Foot	41.08
Overall Plant Efficiency (%)	74
Energy Cost per Hour	11.67
Water Horsepower, hp	62.67
Flow Velocity, ft/sec	6.28